

## **Lab inspection ESL 3 & 4 on Tuesday Nov. 6<sup>th</sup>, 2007**

Stefan Sellner (chair)

Anthony O'Brien

Emre Togan

Don Claflin

### **301**

- No Chemtracker signs yet
- NO FOOD sign on Microwave oven falls off, has to be reattached

### **305**

- NO FOOD label on microwave missing
- No Chemtracker signs yet

### **328**

- one unused compressed gas cylinder without cap
- No Chemtracker signs yet

### **326/327**

- unused and uncapped gas cylinders
- bicycle in the lab
- No Chemtracker signs yet

### **325**

- unsecured gas cylinder
- open toed shoes being worn in the Laboratory
- No Chemtracker signs yet
- No Emergency Response Guide in Lab (or at least no one close to the phone)

### **324**

- No Chemtracker signs yet
- ok

### **323**

- No Chemtracker signs yet
- ok

### **322**

- No Chemtracker signs yet
- compressors hoses across floor, tripping hazard
- lots of other things on the floor (computer screen, printer, more compressors)
- power cord running under door outside the Laboratory

### **415**

- only small NO FOOD sign on Microwave
- defrost refrigerator (for Food and drinks), door does not close or open, ice melting onto floor
- box for fire blanket blocked by large Freezer
- hazardous waste not in secondary containers
- empty containers (glass and plastic) stored on floor, electrical room (416) cannot be opened
- larger sign for eyewash/shower
- bio-hazardous waste containers have to be emptied
- general impression: Lab very messy

### **420**

- ok

### **405**

- ok

### **403**

- ok

### **406**

- there is no eye wash in the Lab, they have to use the one in Lab 415
- not enough space for all the equipment which is partially blocking the electrical rooms (unaccessible) and flammable cabinets (storage issue)